FDC - L41 *1/4 DIN HIGH LIMIT*

FDC - L41

Schedule A	1	2	3	4	5	6	7

1. POWER INPUT

4: 90-250 VAC 50/60 HZ
5: 11-26VAC/VDC
9: Special Order

2. SIGNAL INPUT - see note at bottom right on FM Approval & VDC/mA inputs

1: Universal Input T/C, RTD, mV (0-60mV)
2: Voltage DC: 0-1*
3: Voltage DC: 0-10*
4: mA: 4-20, 0-20*
5: Voltage DC: 1-5, 0-5*
9: Special Order*

3. OUTPUT 1

1: Form C Relay (SPDT) -
2 Amps @ 240VAC resistive
2: SSR drive 5 VDC @30 mA
6: Triac - 1 Amp @ 240VAC solid state relay
C: SSR drive 14 VDC @40 mA
9: Special Order

4. OUTPUT 2

0: None
1: Form C Relay - 2A@240 VAC resistive (SPDT)
2: SSR Drive 5 VDC @30 mA
6: Triac - 1 Amp @ 240VAC solid state relay
7: Transmitter Power Supply 20VDC/25mA (isolated)
8: Transmitter Power Supply 12VDC/40mA (isolated)
9: Transmitter Power Supply 5VDC/80mA (isolated)
C: SSR Drive 14VDC @40mA
H: Special Order

5. COMMUNICATIONS

0: None
1: RS-485 Modbus RTU
2: RS-232 Modbus RTU
3: Retransmission: 0-20/4-20mA, isolated,
500 ohm load min
4: Retransmission: 0-5/1-5VDC, isolated,
10k ohm load min
5: Retransmission: 0-10VDC, isolated,
10k ohm load min
9: Special Order

6. Protective Class

0: IP50 Standard
1: IP65 (Nema 4X)

7. SPECIAL ORDER

Leave Blank unless assigned a specific 2-character Special Order Code

Note: The last digit (codes 7) is typically left blank

File#: E197216 209463 RoHS Compliant

P.O. Box 1196 · Bridgeview, IL 60455
888.751.5444 Sales · 888.307.8014 Fax
Technical Support: 866.342.5332
http://www.futuredesigncontrols.com

September 2024