FDC - L91 1/16 DIN HIGH LIMIT

FDC - L91

Schedule A	1	2	3	4	5

1. POWER INPUT

4: 90-264 VAC 50/60 HZ
5: 11-26VAC/VDC
9: Special Order

2. SIGNAL INPUT*

1: Universal Input T/C, RTD, mV
2: Voltage DC: 0-1
3: Voltage DC: 0-10
4: mA 0-20, 4-20
5: Voltage DC: 0-5, 1-5

3. OUTPUT 1

1: Form C Relay (SPDT) -
2 Amps @ 240VDC resistive (N.O.)
2: SSR drive 5VDC @30 mA
6: Triac - 1 Amp @ 240VAC
C: SSR 14VDC @40mA
9: Special Order

4. OPTIONS

0: None
1: Form A Relay - 2A@240 VAC resistive (N.O.)
2: SSR Drive 5 VDC @30 mA
6: Triac - 1 Amp @ 240VAC
7: Transmitter Power Supply 20VDC/25mA (isolated)
8: Transmitter Power Supply 12VDC/40mA (isolated)
9: Transmitter Power Supply 5VDC/80mA (isolated)
A: RS - 485 (Modbus RTU)
B: Remote Reset
C: SSR Drive 14VDC @40mA
D: Retransmission: 0-20/4-20mA , isolated,
500 ohm load min
E: Retransmission: 0-5/1-5VDC, isolated,
10k ohm load min
F: Retransmission: 0-10VDC, isolated,
10k ohm load min
H: Special Order

5. SPECIAL ORDER

Leave Blank unless assigned a specific 2-character Special Order Code

Note: The last digit (codes 5) is typically left blank

* Instruments ordered with signal inputs 2,3 & 4 are not FM approved.

FDC-L91 DIN Rail Mount Adapter model DRA-16 refer to page 40

File#: E197216 209463 RoHS Compliant

P.O. Box 1196 · Bridgeview, IL 60455
888.751.5444 Sales · 888.307.8014 Fax
Technical Support: 866.342.5332
http://www.futuredesigncontrols.com

6-2024 Changed agency approval
From cUR/US to cUL/UL